



## Motor Check sheet

### Nameplate

Serial number	US134034	Ber number	6306ZZC4X2
Type	KEE-5-6W	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	5 kN	F.L.A.	0.74 A
I.P.	66	R/Min	1135 r/min
kW	0.35 kW	P.F.	69
Insulation	E	Mass	36 kg
Rating	Cont	Sku	87693

### Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

### Continuity Test

Phase A- Gnd	N/A	Phase A-B	96.1 Ω
Phase B-Gnd	N/A	Phase B-C	96.1 Ω
Phase C-Gnd	N/A	Phase A-C	96.1 Ω

Bump Test	Okay
-----------	------



## Motor Check sheet

### Nameplate

Serial number	US068060001	Ber number	6306ZZC4X2
Type	KEE-5-6W	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	5 kN	F.L.A.	0.74 A
I.P.	66	R/Min	1135 r/min
kW	0.35 kW	P.F.	69
Insulation	E	Mass	36 kg
Rating	Cont	Sku	87693

### Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

### Continuity Test

Phase A- Gnd	N/A	Phase A-B	87.8 Ω
Phase B-Gnd	N/A	Phase B-C	87.8 Ω
Phase C-Gnd	N/A	Phase A-C	87.8 Ω

Bump Test	Okay
-----------	------



## Motor Check sheet

### Nameplate

Serial number	US091042003	Ber number	6306ZZC4X2
Type	KEE-5-6W	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	5 kN	F.L.A.	0.74 A
I.P.	66	R/Min	1135 r/min
kW	0.35 kW	P.F.	69
Insulation	E	Mass	36 kg
Rating	Cont	Sku	87693

### Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

### Continuity Test

Phase A- Gnd	N/A	Phase A-B	96.4 Ω
Phase B-Gnd	N/A	Phase B-C	96.4 Ω
Phase C-Gnd	N/A	Phase A-C	96.4 Ω

Bump Test	Okay
-----------	------