



Motor Check sheet

Nameplate

| | | | |
|-----------------|-------------|------------|------------|
| Serial number | US091045001 | Ber number | NJ314EC3X2 |
| Type | KEE-45-6BW | Voltage | 575 |
| Phase | 3 | Hertz | 60 Hz |
| Vibrating force | 45 kN | F.L.A. | 4.6 A |
| I.P. | 66 | R/Min | 1145 r/min |
| kW | 3.7 kW | P.F. | 77 |
| Insulation | E | Mass | 213 |
| Rating | Cont | Sku | 87694 |

Insulation Test

| | | | |
|--------------|--------|-----------|-----|
| Phase A- Gnd | >11 GΩ | Phase A-B | N/A |
| Phase B-Gnd | >11 GΩ | Phase B-C | N/A |
| Phase C-Gnd | >11 GΩ | Phase A-C | N/A |

Continuity Test

| | | | |
|--------------|-----|-----------|-------|
| Phase A- Gnd | N/A | Phase A-B | 4.2 Ω |
| Phase B-Gnd | N/A | Phase B-C | 4.2 Ω |
| Phase C-Gnd | N/A | Phase A-C | 4.2 Ω |

| | |
|-----------|------|
| Bump Test | Okay |
|-----------|------|