



Motor Check sheet

Nameplate

Serial number	US06X049001	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.9 Ω
Phase B-Gnd	N/A	Phase B-C	49.9 Ω
Phase C-Gnd	N/A	Phase A-C	49.9 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US06X049002	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.9 Ω
Phase B-Gnd	N/A	Phase B-C	49.9 Ω
Phase C-Gnd	N/A	Phase A-C	49.9 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US06Z043	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	50 Ω
Phase B-Gnd	N/A	Phase B-C	50 Ω
Phase C-Gnd	N/A	Phase A-C	50 Ω

Bump Test Okay



Motor Check sheet

Nameplate

Serial number	US08Y090002	Ber number	Unknown
Type	KEE-9-6	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	Unknown	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	Unknown	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.8 Ω
Phase B-Gnd	N/A	Phase B-C	49.8 Ω
Phase C-Gnd	N/A	Phase A-C	49.8 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US068053001	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.1 Ω
Phase B-Gnd	N/A	Phase B-C	49.1 Ω
Phase C-Gnd	N/A	Phase A-C	49.1 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US068053002	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.3 Ω
Phase B-Gnd	N/A	Phase B-C	49.3 Ω
Phase C-Gnd	N/A	Phase A-C	49.3 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US069102001	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.5 Ω
Phase B-Gnd	N/A	Phase B-C	49.5 Ω
Phase C-Gnd	N/A	Phase A-C	49.5 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US091047003	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.6 Ω
Phase B-Gnd	N/A	Phase B-C	49.6 Ω
Phase C-Gnd	N/A	Phase A-C	49.6 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US091047004	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.4 Ω
Phase B-Gnd	N/A	Phase B-C	49.4 Ω
Phase C-Gnd	N/A	Phase A-C	49.4 Ω

Bump Test	Okay
-----------	------



Motor Check sheet

Nameplate

Serial number	US091047005	Ber number	6308ZZC4X2
Type	KEE-9-6BW	Voltage	575
Phase	3	Hertz	60 Hz
Vibrating force	9 kN	F.L.A.	1.2 A
I.P.	66	R/Min	1130 r/min
kW	0.6 kW	P.F.	67.4
Insulation	E	Mass	54 kg
Rating	Cont	Sku	87703

Insulation Test

Phase A- Gnd	>11 GΩ	Phase A-B	N/A
Phase B-Gnd	>11 GΩ	Phase B-C	N/A
Phase C-Gnd	>11 GΩ	Phase A-C	N/A

Continuity Test

Phase A- Gnd	N/A	Phase A-B	49.4 Ω
Phase B-Gnd	N/A	Phase B-C	49.4 Ω
Phase C-Gnd	N/A	Phase A-C	49.4 Ω

Bump Test	Okay
-----------	------